

Committente:

PARMA CALCIO 1913 srl

Borgo 20 Marzo, 4 – 4312 Parma (PR)

**REALIZZAZIONE DI NUOVO CAMPO SPORTIVO PRESSO IL CENTRO
SPORTIVO “IL NOCE”, VIA A.SORDI – NOCETO (PR)**

Documentazione attinente alla riduzione del rischio sismico necessaria
per il rilascio del permesso di costruire (ai sensi D.G.R.E.R. 1373/2011)

ELABORATI GRAFICI

Data: 22 Giugno 2026

Revisione: 1.00

Codice commessa interno: -----



DESCRIZIONE DEGLI ELABORATI GRAFICI ALLEGATI

Nella attuale fase di progettazione sono già a disposizione del sottoscritto gli elaborati grafici in elevazione di tutte e tre le componenti strutturali ed in particolare:

- ELABORATO IN PIANTA ED IN SEZIONE DEI PREFABBRICATI USO SPOGLIATOI;
- ELABORATO IN PIANTA ED IN SEZIONE DELLA TRIBUNA PREFABBRICATA E DELLA CORRISPONDENTE COPERTURA;
- ELABORATO TECNICO DELLA TORRE FARO.

Si allegano alla presente, indicando per le prime due la posizione della platea di fondazione.

IL Tecnico


Ing. Giovanni Nesti



ALLEGATI:

- ELABORATO GRAFICO RELATIVO ALLE STRUTTURE DI FONDAZIONE DEGLI SPOGLIATOI PREFABBRICATI – con campitura verde la platea di fondazione;
- ELABORATO GRAFICO RELATIVO ALLE STRUTTURE IN ELEVAZIONE DEGLI SPOGLIATOI PREFABBRICATI;
- ELABORATO GRAFICO RELATIVO ALLE STRUTTURE IN ELEVAZIONE DELLE TRIBUNE E DELLE CORRISPONDENTI COPERTURA– con campitura verde la platea di fondazione;
- ELABORATO GRAFICO DEL SISTEMA DI FONDAZIONE DELLE TORRI FARO;

3,05 m H. Est.



Dimensioni - Dimensions in [mm]

NEW HOUSE S.p.A.

TERMOIDRAULICA E CONDIZIONAMENTO DAL 1959

ENGINEERING

VIA DORDONE - 41 LEGGARA (PARMA) - ITALY
Tel. +39 0525 431680 - Fax +39 0525 431690
www.newhouse.it - e-mail: info@newhouse.it

CLIENTE - CUSTOMER

RENATO MONICA (PR)

DESCRIZIONE - FILE

261044A-PLANPROSP-RO3

OFFERTA - BID "N°"

ORDINE - ORDER "N°"

COMMESSE - JOB "N°"

SCALA - SCALE

FORMATO - PAGE

Azienda ricevente di qualità
EN ISO 9001:2008
Certificazione n° 8734

2500741

261044

261044A

1:50

A0

REVISIONI - DRAWING ISSUE RECORD

DATA DATE	N°	REDAZIONE EDITION	VERIFICATO CHECKED	OGGETTO DELLA REVISIONE ISSUE SUBJECT
20/04/2021	0	N. Frati	N. Frati	EMISSIONE PER APPROVAZIONE
01/06/2020	1	Frati	Frati	Modifica dolce arbitri
04/06/2020	2	Frati	Frati	Invertito e spezzato il componibile a seguito della riunione del 04/06/2020
10/06/2020	3	Frati	Frati	Aumentato suq. spogliatoi atleti e doccia arbitri
	4			


NOTE PER L'ESECUZIONE

TOLLERANZE: ± 2 mm PENDENZE: ± 2 % UNITÀ DI MISURA: QUOTE [mm] ANGOLI [°]

Il presente disegno è di proprietà di New House S.p.A. Non può essere copiato, riprodotto o messo a terzi senza nostra approvazione scritta.
New House S.p.A. persegua una nobile e legale fusa non autorizzato per presente disegno.
This drawing is the property of New House S.p.A. Any copy, reproduction and/or distribution without New House approval is unlawful.
New House S.p.A. will protect it's rights according to current rules and/or for unauthorized use of this drawing

scala 1:100

scala 1:50
6700



Via Grumello, 47/49
24127 BERGAMO - ITALY-
Tel +39 035/4548511 - Fax +39 035/261622
Internet: www.ceta.it - E-mail: ceta@ceta.it

Il presente documento è tutelato dalla Legge sui Diritti d'Autore (Legge 22.4.1942, n. 633) e dalla speciale Legge del 14.12.1982.
E' per tanto vietata la riproduzione arbitraria, anche parziale dello stesso, o la sua diffusione con un mezzo qualsiasi senza il consenso scritto della CETA Spa.

	<i>Cliente</i>
--	----------------

PARMA CALCIO

	<i>Tipologia</i>
--	------------------

G2M6-1 - 196 POSTI SU SET CON COPERTURA A SBALZO

Disegnato

L.Scafili

	<i>Data</i>
--	-------------

03/09/2025

Disegno n°

	<i>Controllato</i>
--	--------------------

	<i>Scala</i>
--	--------------

1:100 1:50 1:20


	<i>Categoria</i>
--	------------------

Rev.

	<i>Approvato</i>
--	------------------

	<i>Cantiere</i>
--	-----------------

PARMA (PR)



POLE FOUNDATION ELEV.
SCALE: NOT TO SCALE

POLE FOUNDATION SCHEDULE					
POLE DESIGNATION	FORCES			DRILLED PIER	
	MOMENT (M) N-m	SHEAR (V) N	VERTICAL (P) N (1.)	MINIMUM DIAMETER mm	EMBEDMENT mm
S1 - S4	71,080	5,079	8,700	750	4265

1. WEIGHT OF POLE, FIXTURES AND ACCESSORIES.

PRECAST BASE IDENTIFICATION					
PRECAST BASE TYPE	PRECAST BASE WEIGHT	PRECAST BASE LENGTH	PROJECTION ABOVE GRADE	STANDARD EMBEDMENT	OUTSIDE DIAMETER
4B	15,525 N	6705 mm	2440 mm	4265 mm	400 mm

POLE IDENTIFICATION				
POLE DESIGNATION	POLE TYPE	PRECAST BASE TYPE	FIXTURE CONFIGURATION (FIX. PER XARM)	FIXTURE AND ACCESSORIES EPA (m ²)
S1 - S4	LSS70C	4B	4 (4)	1.09

DESIGN NOTES

DESIGN PARAMETERS:
WIND: 25 m/s (TERRAIN CATEGORY II) PER EUROPEAN STANDARD EN 40-3-1:2013

GEOTECHNICAL PARAMETERS:
ALLOWABLE END BEARING SOIL PRESSURE: 72 kPa
ALLOWABLE LATERAL SOIL BEARING PRESSURE: 0 kPa/m (GRADE TO -0.6 m); 39 kPa/m (-0.6 m TO -1.0 m); 47 kPa/m (-1.0 m TO -3.2 m); 58 kPa/m (BELOW -3.2 m)
IN ACCORDANCE WITH THE 2021 EDITION OF THE INTERNATIONAL BUILDING CODE, CHAPTER 18.

REFERENCE GEOTECHNICAL ABSTRACT PREPARED BY FABIO BUSSETTI - STUDIO GEOLOGICO AMBIENTALE ; PARMA, ITALY.

A GEOTECHNICAL ENGINEER OR REPRESENTATIVE OF IS RECOMMENDED (NOT REQUIRED) TO BE AVAILABLE AT THE TIME OF THE FOUNDATION INSTALLATION TO VERIFY THE SOIL DESIGN PARAMETERS AND TO PROVIDE ASSISTANCE IF ANY PROBLEMS ARISE IN FOUNDATION INSTALLATION.

ENCOUNTERING SOIL FORMATIONS THAT WILL REQUIRE SPECIAL DESIGN CONSIDERATIONS OR EXCAVATION PROCEDURES MAY OCCUR. POLE FOUNDATIONS WILL NEED TO BE ANALYZED ACCORDING TO THE SOIL CONDITIONS THAT EXIST. IF ANY DISCREPANCIES OR INCONSISTENCIES ARISE, NOTIFY THE ENGINEER OF SUCH DISCREPANCIES. FOUNDATIONS WILL THEN BE REVISED ACCORDINGLY. REVISIONS WILL BE ANALYZED PER RECOMMENDATIONS DIRECTED BY A REGISTERED ENGINEER.

ALL EXCAVATIONS MUST BE FREE OF LOOSE SOIL AND DEBRIS PRIOR TO FOUNDATION INSTALLATION AND CONCRETE BACKFILL PLACEMENT. CONTRACTOR SHOULD BE PREPARED FOR THE POSSIBILITY OF GROUND WATER PUMPING AND EXCAVATION STABILIZATION AS CONDITIONS MAY REQUIRE. CASINGS OR DRILLERS SLURRY MAY BE USED TO STABILIZE THE EXCAVATION DURING INSTALLATION. TEMPORARY CASINGS MUST BE REMOVED DURING CONCRETE BACKFILL PLACEMENT. PERMANENT CASINGS MUST BE SMOOTH-SIDED STEEL PIPE, AND MUST BE INSERTED INTO PLACE FIRST PRIOR TO CLEANING OUT THE INSIDE SO THAT CONTINUOUS CONTACT WITH THE SURROUNDING UNDISTURBED SOILS IS MAINTAINED.

CONCRETE BACKFILL MUST BE PLACED WITH A TREMIE WHEN SLURRY OR WATER IS PRESENT WITHIN THE EXCAVATION. THE MOUTH OF THE TREMIE MUST REMAIN BURIED IN FRESH CONCRETE SO THAT THE CONCRETE DISPLACES WATER OR SLURRY WITHOUT MIXING.

CONCRETE:
CONCRETE SHALL BE AIR-ENTRAINED AND HAVE A MINIMUM COMPRESSIVE DESIGN STRENGTH AT 28 DAYS OF 20 MPa. POLE ERECTION MAY TAKE PLACE AFTER STRENGTH GAIN HAS REACHED 7 MPa MINIMUM, OR 24 HOURS HAVE ELAPSED FROM PLACEMENT. ALL PIERS AND CONCRETE BACKFILL MUST BEAR ON AND AGAINST FIRM UNDISTURBED SOIL, OR PERMANENT CASINGS WHERE UTILIZED.

GENERAL NOTES:
FIXTURES MUST BE LOCATED TO MAINTAIN 3.0 m MINIMUM HORIZONTAL CLEARANCE FROM ANY OBSTRUCTION. ENGINEER MUST BE NOTIFIED IF FOUNDATIONS ARE NEAR ANY RETAINING WALLS OR WITHIN / NEAR ANY SLOPES STEEPER THAN 3H : 1V. POLES, FIXTURES, PRECAST BASES, ELECTRICAL ITEMS AND INSTALLATION PER MUSCO LIGHTING.



I HEREBY CERTIFY THAT THIS ENGINEERING DOCUMENT WAS PREPARED BY ME OR UNDER MY DIRECT PERSONAL SUPERVISION AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF IOWA.

Casey A. Wyatt - NO. P25065 DATE: 05/14/2026

LICENSE RENEWAL DATE: DECEMBER 31, 2027
DRAWING NO. COVERED BY THIS SEAL: C1

PARMA CALICO 1913
NEW TRAINING GROUND
FIELD LIGHTING
PARMA, ITALY

MUSCO Lighting
CORPORATE: 100 1st AVE WEST
OSKALOOSA, IA 52577
(800) 825-6020

STRUCTURAL ENGINEERS, P.C.
114 NICHOLAS DRIVE
MARSHALLTOWN, IOWA 50158
PHONE NUMBER: 641-752-6334
EMAIL: MSL.INFO@SEPC.BIZ

DRAWING TITLE: POLE AND FOUNDATION	SCALE: SEE PLAN	NOTES: SCAN #215307A
PROJECT NUMBER 215307		
DATE 14 MAY 2026		
DRAWING NUMBER C1		
OF ONE		